

# CSO Control Options

## 1. Store peak flows

during large storms and send to the existing treatment plant after the storm.



*Excavation nearly complete for a 400,000 gallon storage tank in Blaine, WA*

## 2. Increase pumping and conveyance to direct peak flows to existing treatment facilities.



*New pump station under construction*

## 3. Reduce peak flows of storm water and ground water into the combined sewer system.



*Rain barrels keep peak flows out of sewers*

## 4. Treat peak flows at a new local treatment facility.



*CSO treatment facility in Bremerton, WA, showing top of underground storage tank on the right and treatment building*

## 5. Use combinations of the options.